

## How to report the code #58 / #53 of an Aqua-Protec system

### Procedure

1. Press the **"ok"** button twice to access the main menu
2. Press on the **down** arrow until you see technician appear
3. Enter your technician number to enter the Aqua-Protec settings
4. Press on the **right** arrow to confirm your choice
5. From the technician menu, press on the down arrow until you are aligned with **"Change RPSM"**
6. Press on the right arrow to confirm selection
7. From the **"Change RPSM"** menu, press on the right to select **"RPSM SN"**
8. Change the first letter of the serial number for one higher (ex: change A to B) by using the up arrow. Then confirmed the change by pressing on the **right** arrow until you get to the previous menu
9. Press on the **down** arrow to be aligned with **"RPSM expiry"**. Press on the **right** arrow to confirm selection
10. The date shown should be 5 years from now. Press on the **right** arrow until it brings you back to the previous menu
11. Press on the **down** arrow until you are aligned with **"Inflating count"**. Press on the right arrow to confirm the selection
12. The number of inflations should be 0. Press on the **right** arrow to confirm and to go back to the previous menu
13. Press **4 times** on the **left** arrow until it brings you back to the home screen.
14. The system should no longer show the code and should indicate **"Aqua-Protec, Date & time, Standby, Sewer free"**

