



HOW TO FIX A LOSS OF SUPERVISION PROBLEM ON THE SENSOR(NOWDSF360)

Necessary Equipment:

- Magnet
- Phillips Precision Screwdriver (Star) #00
- Flat screwdriver



Procedure:

1. Using your small flat screwdriver, remove each of the small plugs located in the center of each leg of the wireless detector, so that you can see each of the star screws.
2. Unscrew these three small screws from the detector legs using the Philips screwdriver.
3. Lift the upper part of the detector, so that it is separated into two parts.
4. Remove the CR2450 battery by gently lifting it using your flathead screwdriver.
5. **Replace the CR2450 battery** in the slot provided for this purpose, **making sure you see the positive side of the battery.**
6. **Make sure to push the metal tab back as far as it will go (See illustration)**



2024/02



7. Place the top and bottom of the detector back together, making sure the gasket is in place. To do this easily, **align the lines that appear on the side of each part of the detector.** This will make it easier to put the small screws joining the two parts back in place in the right place.
8. Screw in the small star screws.
9. **Replace the three small** plugs in the center of each of the detector legs to hide the star screws.
10. **Take the magnet and tap it on the line formed on the side of the detector then remove the magnet.**
Note: If your detector is configured as gel, follow the same step, but this time, hold the magnet in place for 5 seconds.
11. If the magnet is strong enough, your control panel will then notify you of a tamper alarm and correct the low battery signal.
12. You can then press **“Reset”** to cancel the alarm and press **“Open valve”** to reopen the valve.